

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene informacion muy importante sobre su agua potable. Traduzcalo o hable con alguien que lo entienda bien.

Grandview Terrace Water District

Has Levels of Manganese Above the Secondary Drinking Water Standards

Our water system recently violated a secondary drinking water standard. Although this is not an emergency, as our customer, you have a right to know what happened, what you should do, and what we did and are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Water samples we collected on August 28, 2026, show that our system exceeds the standard for manganese. The standard for manganese is 0.10 mg/L. The detected concentration for Grandview Terrace Water District Tank Well was 0.42 mg/L. It is important to note that water from the Tank Well contributes minimally to your water supply and is not indicative of the water you are drinking.

What should I do?

You do not need to use an alternative (e.g., bottled) water supply. Manganese is an aesthetic concern. However, if you have specific health concerns, consult your doctor.

What does this mean?

Manganese may become noticeable in tap water at concentrations greater than 50 parts per billion (ppb) by imparting color, odor or taste to the water. However, health effects from manganese are not a concern until concentrations are approximately 10 times higher. If you have specific health concerns, please consult a health care professional.

What is being done?

We are continuing to review options to bring manganese below allowable levels. As required by the Bureau of Safe Drinking Water and Northern Nevada Public Health, we will continue to take monthly manganese samples to monitor levels.

For more information, please contact:

Responsible Person: Alejandro Sabogal	System Name: Grandview Terrace
Phone Number: 775-830-6943	System PWSID: NV0000035

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Method of distribution: Website Date distributed: 09/21/2026

Public Notification Certification

The public water system named above hereby affirms that public notification has been provided to its consumer in accordance with all delivery, content, format, and deadline requirements specified in NAC 445A.485.


(Signature)

Alejandro Sabogal
(Print Name)

09/21/2026
(Date)